



DELISA^{LTO}

DEscription of the extended Lifetime and its influence on the Safety operation and construction materials performance – Long Term Operation with no compromises in the safety



Report summarizing the survey results, containing selected testing and analytical methods and parameters for the experimental program

4. 2

2022.11.30

Kateřina Rusňáková¹, Radim Kopřiva¹

¹ÚJV Řež, a. s., Hlavní 130, Řež, 250 68 Husinec, Czech Republic

Disclaimer

Funded by the European Union. Views and opinions expressed are however those of the author(s) only and do not necessarily reflect those of the European Union or Euratom. Neither the European Union nor the granting authority can be held responsible for them.



Funded by
the European Union

About DELISA-LTO

The aim of the project is to determine the most affected and threatened components from the point of view of the long-term operation (LTO) and describe the effect of the LTO on the material properties as well as develop a simulation tool able to predict the non-acceptable state of the material. The project is specifically focused on the Water-Water Energetic Reactor (VVER), nevertheless, the approach is to maintain the easy transferability to other light water reactor technologies, as well.

The outputs of the project will lead to the increase of operational safety at the extended lifetime due to the in-time prediction of the potential failure. The basic approach of the project is to combine the development of the simulation tools, experimental work (material analyses), in-service and/or non-destructive inspection techniques to develop the effective “early warning” tool for the assessment of the system integrity for the LTO of the current LWR with a specific focus on the VVER technology.

The project's aim specifically focuses on the thermal aging and swelling of the loaded constructional materials. One of the most affected components from the LTO's point of view are the heat exchanging tubes of steam generators (thermal ageing) and reactor internals (swelling). The experimental material was screened and selected with the main criteria: to support and validate the proposed methods in the most accurate way, and to be “on stock” and available at the expected start of the project, the latest. The experiments are planned to be performed at the available material with clear and well-described operational history as well as the material from the original batch in the “as-received” state to gain the most relevant and valuable information with high impact to the community.

Project information

Project Title	Description of the extended Lifetime and its influence on the Safety operation and construction materials performance – Long Term Operation with no compromises in the safety
Project Acronym	DELISA-LTO
Grant Agreement No.	101061201
Call	HORIZON-EURATOM-2021-NRT-01
Project dates	01. 06. 2022 – 31. 05. 2026
Project duration	48 months
Project website	
Coordinator	Centrum Výzkumu Řež, s.r.o. (Czech Republic)

Partners



Report summarizing the survey results, containing selected testing and analytical methods and parameters for the experimental program

Dissemination level		
PU	Public	X
SEN	Sensitive, limited under the conditions of the Grant Agreement	
EU-R	EU RESTRICTED under the Commission Decision No2015/444	
EU-C	EU CONFIDENTIAL under the Commission Decision No2015/444	
EU-S	EU SECRET under the Commission Decision No2015/444	

Document information					
Deliverable No.&Name	D4.2 - Report summarizing the survey results, containing selected testing and analytical methods and parameters for the experimental program				
Status					
Final (F) / Draft (D) / Revised draft (RV)	F	Due (month)	M6	Date	2022.11.30
Work Package No.	4	Work Package Title	Experimental validation and tests		
Work Packed Leader (Institute Acronym)	UJV				
Description of the related task and the deliverable	Report summarizing the survey results, containing selected testing and analytical methods and parameters for the experimental program. Deliverable serves as a basis for the experimental material matrix preparation.				
Comments	-				
Reviewers	-				
V	Date	Author(s)	Description		
0	2022.11.30	Radim Kopřiva, Kateřina Rusňáková	Initial document		

Content

- Content..... 4
- 1. Background..... 5
- 2. Introduction..... 5
- 3. Methodology 5
- 4. Results / Data summary 6
- 5. Conclusions 6

1. Background

The goal of the Deliverable D4.2, realized within the WP4, Task 4.1, is to summarize obtained data from the survey and questionnaires into the experimental testing matrix frame. After evaluation of the collected data, it is possible to create testing material matrix frame that includes priorities, preferences and testing capabilities of all participating laboratories.

This output enables the opportunity of available testing methods and preferred specimen geometries connection with available archive structural materials to develop the detailed system of experimental interlaboratory studies. Due to the very close interconnection of work packages, the obtained data will be utilized within the WP4 – “Experimental validation and tests” as well as WP2 – “Methodology and assessment”.

2. Introduction

The first part of the two-round questionnaires (Deliverable D4.1, WP4) was focused on the collection of information about participating laboratories accreditation and quality assurance system (A1) and used testing methods (A2). After obtaining of the data from the first round of survey, it was possible to prepare more detailed second round of questionnaires.

For every experimental testing method additional more detailed questionnaire (Annex 1) was created. These more comprehensive questionnaires were sent to contributing partners in WP4. Completed questionnaires were subsequently evaluated by the WP4 leader and were summarized in the prepared Experimental matrix frame (Annex 2).

3. Methodology

The first part of the two round questionnaire was divided into two parts - A – “Experimental testing” and B – “Non-destructive testing”. The sub-part A1 includes information about experimental testing accreditation and B1 is focused on non-destructive testing certification and site qualification. The subpart A2 includes experimental testing methods and B2 non-destructive testing methods. The second part of the survey – more detailed questionnaires were sent to contributing partners based on data from Table 1.

Detailed questionnaires were used for the frame of experimental testing matrix preparation (Annex 2). In general, the frame of the experimental matrix combines experimental testing and analytical techniques, participating laboratories, experimental archive material and preferred specimen type of each contributing partner and testing methodology. Specimen types are divided into standard and miniaturized specimen types for the planned comparison of conventional methods with perspective approaches using sub-sized specimens.

Selected experimental and analytical methods will be connected with the available archive material inventory to create the detailed system of experimental interlaboratory studies. Materials were selected within the WP2 from different primary circuit components of the NPP Jaslovske Bohunice (Units 1 and 2) with respect to the structural material state (initial state/number of years in operation) and material type – base metal (BM), weld metal (WM) and heat affective zone (HAZ). Experimental matrix will also serve as a basis for the thermal ageing phenomenon evaluation, thus accelerated thermal ageing in laboratory conditions is also considered.

4. Results / Data summary

The Table 1 summarizes obtained data from first round of the questionnaire. Green cells of the table indicate which testing method is accredited. The table gives an overview about available testing and analytical methodologies in participating laboratories. Based on the results presented in the Table 1, more detailed questionnaires were prepared and distributed to WP4 members (Annex 1).

After the second round of questionnaires collection, evaluated data were used for the preparation of the experimental matrix frame. Experimental matrix will be completed by participating laboratories subsequently to be a fundamental basis for the WP4 inter-laboratory experimental program. Completion of the experimental matrix will be achieved no later than M12 (May 2023, Milestone MS4.1 – “Methods and experimental plans ready”).

Table 1 - Obtained data from the first questionnaire (Task 4.1 - Deliverable D4.1)

Experimental equipment and methods matrix								
A1 – Experimental testing – Accreditation								
Partner	CVR	IPP	STUBA	EK-CER	UJV	VUJE	VTT	BZN
Laboratory accredited	-	-	-	✓	✓	✓	✓	✓
Accreditation standard	-	-	-	ISO 9001 2015	ISO/IEC 17025 2018	ISO/IEC 17025 2017	ISO/IEC 17025 2017	ISO/IEC 17025 2018
Year of the first accreditation	-	-	-	2012	1995	1998	2010	2020
A2 – Experimental testing – Methods								
Partner	CVR	IPP	STUBA	EK-CER	UJV	VUJE	VTT	BZN
A2.1 – Impact testing	✓	✓	-	✓	✓	-	✓	✓
A2.2 – Tensile testing	✓	✓	-	✓	✓	-	✓	✓
A2.3 – Static fracture toughness	-	✓	-	✓	✓	-	✓	✓
A2.4 – Hardness	✓	✓	✓	✓	✓	✓	✓	✓
A2.5 – Small Punch Test (SPT)	-	✓	-	-	✓	✓	-	✓
A2.6 – Scanning electron microscopy	✓	-	✓	✓	✓	✓	✓	✓
A2.7 – Optical microscopy	✓	-	✓	✓	-	✓	✓	✓
A2.8 – TEM	✓	-	✓	-	-	-	✓	-



- testing method accredited

5. Conclusions

Within the Task 4.1 the Deliverable D4.2 “Report summarizing the survey results, containing selected testing and analytical methods and parameters for the experimental program” was prepared. Collected data provide basis for subsequent planned activities within the Project. Based on the obtained data, the experimental matrix frame was prepared to serve as the fundamental basis for the WP4 experimental program finalization.

Annex 1

Second round of the questionnaires



DELISA-LTO (WP4) – A2.1 – Impact testing

Laboratory _____

A2.1.1 Testing method – Charpy impact testing

- Instrumented testing** Available Non-available
- Standard Charpy–V sample testing** Available (if available complete section A2.1.2) Non-available
- Miniaturized Charpy–V sample testing** Available (if available complete section A2.1.3) Non-available

A2.1.2 Testing machine - standard

Testing machine (model) _____ **Year of installation** _____

Nominal initial potential energy (J) _____ **Resolution (J)** _____

Striker type C - type U – type **Radius of striker (mm)** _____

Max. impact speed (m/s) _____ **Max. angle (°)** _____

Empty swing (J) _____ **Testing temperature range (°C)** _____

Sample positioning and centering method manual automatic

Specimen centering method notch position centering block centering

Additional information - comments:



A2.1.3 Testing machine - miniaturized

Testing machine (model) _____ Year of installation _____

Nominal initial potential energy (J) _____

Resolution (J) _____

Striker type C - type U - type

Radius of striker (mm) _____

Max. impact speed (m/s) _____

Max. angle (°) _____

Empty swing (J) _____

Testing temperature range (°C) _____

Sample positioning and centering method

manual

automatic

Specimen centering method

notch position centering

block centering

Additional information - comments:

A2.1.4 Preferable specimen types and dimensions

Typical (mostly used and preferred) sample geometry – **please provide drawing together with completed questionnaire! If you use more typical specimen geometries, please specify other in comments.**

Standard - Ch-V (10 x 10 x 55 mm)

Sub-sized - mCh-V (5 x 5 x 27,5 mm)

Sub-sized - mCh-V (3 x 4 x 27 mm)

Other

If other specimen types and geometries (e.g., notch type), please specify (with dimensions):



A2.1.5 Specimen preparation

Equipment for specimen preparation

Available

Non-available

(if non-available, please proceed to the A.2.1.6)

Notch cutting method

Electric discharge (EDM) Mechanical Other _____

Specimen reconstitution

Available

Non-available

(if non-available, please proceed to the A.2.1.6)

Reconstitution method (e. g. EBW) _____

Insert dimensions (e. g. 10 x 10 x 14 mm) _____

Please describe the specimen preparation technique:

A2.1.6 Test standards & evaluation

Used standards

ASTM E 23

ISO 148

EN 10045

Other (please specify): _____

Additional comments



DELISA-LTO (WP4) – A2.2 – Tensile testing

Laboratory _____

A.2.2.1 Testing machine and specimens

Testing machine (model) _____ Capacity (kN) _____

Servo-hydraulic Electromechanical Year of installation _____

Load cell capacity (kN) _____

Sensor type Clip-gage LVDT Video extensometer Laser extensometer
 Other (please specify) _____

Testing temperature range (°C) _____

Testing environment Air Inert gas (please specify) _____

Typical (mostly used and preferred) sample geometry – please provide drawing together with completed questionnaire! If you use more typical specimen geometries, please specify other in comments.

Cylindrical Flat

Diameter (mm) _____ Width (mm) _____

Gauge length (mm) _____ Thickness (mm) _____

Total length (mm) _____

Max. diameter (mm) _____

For cylindrical specimens only - Sample alignment (holding)

Threaded (specify, e.g. M12) _____ Tapered

Additional information - comments:



A.2.2.2 Specimen preparation

Equipment for specimen preparation Available Non-available
(if non-available, please proceed to the A.2.2.3)

Finishing method Grinding Polishing Turning

Final surface roughness Ra (μm) _____

Please describe the specimen preparation technique:

A.2.2.3 Data acquisition & test evaluation

Sampling rate (Hz) _____

Used standards ASTM E8/E8M ISO 6892-1 ISO 6892-2

Other (please specify): _____

Additional comments



DELISA-LTO (WP4) – A2.3 – Static fracture toughness

Laboratory _____

A2.3.1 Testing machine

Testing machine (model) _____ Year of installation _____

Servo-hydraulic Electromechanical Other _____

Capacity (kN) _____ Load cell capacity (kN) _____

Sensor type COD LVDT Other _____

Testing temperature range (°C) _____

Additional information - comments:

A2.3.2 Preferable specimen types and dimensions

Typical (mostly used and preferred) sample geometry – please provide drawing together with completed questionnaire! If you use more typical specimen geometries, please specify other in comments.

- | | | |
|--|---|---|
| <input type="checkbox"/> TPB (10 x 10 x 55 mm) | <input type="checkbox"/> mTPB (3 x 4 x 27 mm) | <input type="checkbox"/> CT (0,5T-CT) |
| <input type="checkbox"/> CT (1T-CT) | <input type="checkbox"/> mCT (0,14T-CT) | <input type="checkbox"/> mCT (0,16T-CT) |
| <input type="checkbox"/> RCT | <input type="checkbox"/> Other | |

If other specimen types, please specify (with dimensions):



A2.3.3 Specimen preparation

Equipment for specimen preparation

Available

Non-available

(if non-available, please proceed to the A.2.3.4)

Notch cutting method

Electric discharge (EDM)

Mechanical

Other _____

Specimen reconstitution

Available

Non-available

(if non-available, please proceed to the A.2.3.4)

Reconstitution method (e. g. EBW) _____

Insert dimensions (e. g. 10 x 10 x 14 mm) _____

Please describe the specimen preparation technique:

A2.3.4 Test standards & evaluation

Sampling rate (Hz) _____

Used standards

ASTM E399

ASTM E 1820

ISO 12737

ISO 12135

ESIS P2/9D

ASTM E 1921

Other (please specify): _____

Additional comments



DELISA-LTO (WP4) – A2.4 – Hardness

Laboratory _____

A2.4.1 Testing machine

Testing machine (model) _____ Year of installation _____

A2.4.2 Testing method - Vickers (HV)

Available Non-available (if non-available, please proceed to A2.4.3)

HV range (e. g. HV1 – HV 30) _____

Used standards ASTM E92 ISO 6507

Other (please specify): _____

A2.4.3 Testing method - Brinell (HB)

Available Non-available (if non-available, please proceed to A2.4.4)

Indenter Steel ball Tungsten carbide ball

Used standards ASTM E10 ISO 6506

Other (please specify): _____

A2.4.4 Testing method - Rockwell (HR)

Available Non-available (if non-available, please proceed to A2.4.5)

Indenter Diamond cone (HRA/HRC) Steel Ball (HRB)

Used standards ASTM E18 ISO 6508

Other (please specify): _____



A2.4.5 Testing method - Knoop

Available Non-available (if non-available, please proceed to A2.4.6)

Used standards ASTM E92 ISO 4545

Other (please specify): _____

A2.4.6 Specimen preparation

Surface machining (finishing method)

Grinding Polishing Other (please specify): _____

Final specimen surface roughness Ra (μm) _____

A2.4.7 Microhardness or nano-hardness

Microhardness or nano-hardness - if available, please specify parameters:

Additional comments



DELISA-LTO (WP4) – A2.5 – Small Punch Test (SPT) Laboratory _____

A2.5.1 Testing machine

Testing machine (model) _____ Capacity (kN) _____

Servo-hydraulic Electromechanical Year of installation _____

Testing temperature range (°C) _____

A2.5.2 Testing fixture

Receiving hole edge Chamfer Radius Nominal dimension (mm) _____

Real dimension (mm) _____

Indenter Punch Ball Nominal diameter (mm) _____

Real diameter (mm) _____

A2.5.3 Displacement measurement

Deflection Punch displacement Cross-head displacement Other

If other than deflection, please specify testing apparatus stiffness correction method:

A2.5.4 Specimen preparation

Equipment for specimen preparation Available Non-available
(if non-available, please proceed to the A.2.5.5)

Initial cutting method Electric discharge (EDM) Mechanical Other _____

Initial thickness after cutting (mm) _____

Final specimen surface roughness Ra (µm) _____



Please describe the specimen preparation technique and specimen thickness measurement procedure:

A2.5.5 Data acquisition & analysis

Data acquisition – **sampling rate** (Hz) _____

Pre-load used no yes - pre-load used (N) _____

F_e and u_e determination bilinear method trilinear method offset t/10 offset t/100

Yield strength determination EN 10371 (Annex D) In-house correlations (i.e., ASTM E3205)

UTS determination EN 10371 (Annex C) In-house correlations (i.e., ASTM E3205)

End of the test criterion 0.8 · F_m Other _____

Please describe the data treatment procedure:

Additional comments



DELISA-LTO (WP4) – A2.6 – SEM

Laboratory _____

A2.6.1 Testing machine

Testing machine (model) _____ Year of installation _____

A2.6.2 Detectors

Available Detectors SE BSE EDS WDS EBSD Other

Simultaneous detector analyses Available Non-available

If other detectors are available and suitable, please specify:

A2.6.3 Parameters

Used magnification range _____ Image resolution range _____

Accelerated voltage operation modes _____

Working distance for analysis (mm) _____

Max. size of analyzed specimen (dimensions) (mm) _____

Low vacuum mode Available Non-available

A2.6.4 Specimen preparation

Please, describe specimen preparation procedure (e. g. cleaning – ultrasonic, compressed air; etching):



Additional comments



DELISA-LTO (WP4) – A2.7 – Optical Microscopy

Laboratory _____

A2.7.1 Testing machine

Testing machine (model) _____ Year of installation _____

Microscope type (e. g. Stereo, Inverted) _____

A2.7.2 Imaging methods

Bright Field Available Non-available

Dark Field Available Non-available

Polarizer Available Non-available

If other imaging methods are available and suitable, please specify:

A2.7.3 Parameters

Used magnification range _____ Image resolution range _____

Lens types _____

Used SW _____

SW tool for image evaluation _____

Image focus in Z-axis Available Non-available

Motorized table support Available Non-available



A2.7.4 Specimen preparation

Please, describe specimen preparation procedure (e. g. cleaning – ultrasonic, compressed air; etching):

Additional comments



DELISA-LTO (WP4) – A2.8 – TEM

Laboratory _____

A2.8.1 Testing machine

Testing machine (model) _____ Year of installation _____

A2.8.2 Additional analytical methods

STEM (Scanning Transmission Electron Microscopy) Available Non-available

EELS (Electron Energy Loss Spectrometry) Available Non-available

EDS (Energy Dispersive Spectroscopy) Available Non-available

In Situ TEM Available Non-available

Detector types in STEM BF DF HAADF

Camera **Type** _____ **Resolution range** _____

Video recording Available Non-available

Tomography Available Non-available

If other additional analytical methods are available and suitable, please specify:



A2.8.3 Parameters

Used magnification range _____ Image resolution range _____

Maximum specimen thickness (nm) _____

Accelerated voltage operation modes _____

A2.8.4 Specimen preparation



Please, describe specimen preparation procedure (e. g. cleaning – ultrasonic, compressed air; etching):

Additional comments

Annex 2

Experimental matrix frame

DELISA-LTO – WP2/WP4 Experimental matrix		Experimental Technique		A2.2 - Tensile Testing					
		Available / Participating Laboratory		CVR	IPP	EK-CER	UJV	VTT	BZN
Material No.	Material (description)	Material Type	Material state / Specimen geometry	ST	ST	ST	ST	ST	ST
1	Main circulation piping - 08Ch18N12T - NPP V1 – initial state	BM	As received						
			Thermal Aged						
2	Pressurizer surge line - 08Ch18N10T - NPP EBO3 – initial state	BM	As received						
			Thermal Aged						
3	Main circulation piping - 08Ch18N12T+WM - NPP V1 – after 28 years in operation	BM	As received						
			Thermal Aged						
		WM	As received						
			Thermal Aged						
		HAZ	As received						
			Thermal Aged						
4	Main circulation piping – triple T-junction - 08Ch18N12T+WM - NPP V1 – after 28 years in operation	BM	As received						
			Thermal Aged						
		WM	As received						
			Thermal Aged						
		HAZ	As received						
			Thermal Aged						
5	Pressurizer surge line - 08Ch18N10T - NPP V1 – after 28 years in operation	BM	As received						
			Thermal Aged						

-  Accredited method
-  Participation in round robin
- ST** Standard specimen geometry
- M** Miniturized specimen
- BM** Base metal
- WM** Weld metal
- HAZ** Heat affected zone

Specimen type / method

preferred standard geometry of tensile specimens with the diameter 4-8 mm (based on the survey results)

DELISA-LTO – WP2/WP4 Experimental matrix		Experimental Technique		A2.3 - Static Fracture Toughness									
		Available / Participating Laboratory		IPP		EK-CER		UJV		VT		BZN	
Material No.	Material (description)	Material Type	Material state / Specimen geometry	ST	M	ST	M	ST	M	ST	M	ST	M
1	Main circulation piping - 08Ch18N12T - NPP V1 – initial state	BM	As received										
			Thermal Aged										
2	Pressurizer surge line - 08Ch18N10T - NPP EBO3 – initial state	BM	As received										
			Thermal Aged										
3	Main circulation piping - 08Ch18N12T+WM - NPP V1 – after 28 years in operation	BM	As received										
			Thermal Aged										
		WM	As received										
3c	HAZ	As received											
4	Main circulation piping – triple T-junction - 08Ch18N12T+WM - NPP V1 – after 28 years in operation	BM	As received										
			Thermal Aged										
		WM	As received										
4c	HAZ	As received											
5	Pressurizer surge line - 08Ch18N10T - NPP V1 – after 28 years in operation	BM	As received										
			Thermal Aged										

- Accredited method
- Participation in round robin
- ST** Standard specimen geometry
- M** Miniturized specimen
- BM** Base metal
- WM** Weld metal
- HAZ** Heat affected zone

Specimen type / method

TPB (10 x 10 x 55 mm)
mTPB (3 x 4 x 27 mm), mCT (0,16T-CT)
TPB (10 x 10 x 55 mm)
mCT (0,16T-CT)
TPB (10 x 10 x 55 mm), CT (0,5T-CT)
mCT (0,16T-CT)
CT (0,5T-CT)
mCT (0,14T-CT)
TPB (10 x 10 x 55 mm), CT (0,5T-CT)
mTPB (3 x 4 x 27 mm), mCT (0,16T-CT)

DELISA-LTO – WP2/WP4 Experimental matrix		Experimental Technique		A2.4 - Hardness								
		Available / Participating Laboratory		CVR		IPP	STUBA	EK-CER	UJV	VUJE	VTT	BZN
Material No.	Material (description)	Material Type	Material state / Specimen geometry	ST	M	ST	M	ST	ST	ST	ST	ST
1	Main circulation piping - 08Ch18N12T - NPP V1 – initial state	BM	As received									
			Thermal Aged									
2	Pressurizer surge line - 08Ch18N10T - NPP EBO3 – initial state	BM	As received									
			Thermal Aged									
3	Main circulation piping - 08Ch18N12T+WM - NPP V1 – after 28 years in operation	BM	As received									
			Thermal Aged									
		WM	As received									
			Thermal Aged									
		HAZ	As received									
			Thermal Aged									
4	Main circulation piping – triple T-junction - 08Ch18N12T+WM - NPP V1 – after 28 years in operation	BM	As received									
			Thermal Aged									
		WM	As received									
			Thermal Aged									
		HAZ	As received									
			Thermal Aged									
5	Pressurizer surge line - 08Ch18N10T - NPP V1 – after 28 years in operation	BM	As received									
			Thermal Aged									

- Accredited method
- Participation in round robin
- ST** Standard specimen geometry
- M** Miniturized specimen
- BM** Base metal
- WM** Weld metal
- HAZ** Heat affected zone

Specimen type / method

Vickers HV0.01-HV10
Nano-indentation
Vickers HV100-HV1000
Nano-indentation
Vickers HV0.2-HV30
Vickers HV5
Vickers HV0.5-HV120
Vickers HV0.01-HV10
HV0.05-HV20

DELISA-LTO – WP2/WP4 Experimental matrix		Experimental Technique		A2.5 - SPT			
		Available / Participating Laboratory		IPP	UJV	VUJE	BZN
Material No.	Material (description)	Material Type	Material state / Specimen geometry	M	M	M	M
1	Main circulation piping - 08Ch18N12T - NPP V1 – initial state	BM	As received				
			Thermal Aged				
2	Pressurizer surge line - 08Ch18N10T - NPP EBO3 – initial state	BM	As received				
			Thermal Aged				
3	Main circulation piping - 08Ch18N12T+WM - NPP V1 – after 28 years in operation	BM	As received				
			Thermal Aged				
		WM	As received				
			Thermal Aged				
		HAZ	As received				
			Thermal Aged				
4	Main circulation piping – triple T-junction - 08Ch18N12T+WM - NPP V1 – after 28 years in operation	BM	As received				
			Thermal Aged				
		WM	As received				
			Thermal Aged				
		HAZ	As received				
			Thermal Aged				
5	Pressurizer surge line - 08Ch18N10T - NPP V1 – after 28 years in operation	BM	As received				
			Thermal Aged				

Specimen type / method	
■ Accredited method	SPT 8 x 0,5 mm, Radius R0,2, Punch
■ Participation in round robin	SPT 8 x 0,5 mm, Radius R0,2, Punch
■ ST Standard specimen geometry	SPT 8 x 0,5 mm, Radius R0,2, Punch
■ M Miniturized specimen	SPT 8 x 0,5 mm, Radius R0,2, Punch
■ BM Base metal	SPT 8 x 0,5 mm, Chamfer 0,2 x 45°, Ball
■ WM Weld metal	
■ HAZ Heat affected zone	



DELISA-LTO – WP2/WP4 Experimental matrix		Experimental Technique		A2.6 - Scanning Electron Microscopy						
		Available / Participating Laboratory		CVR	STUBA	EK-CER	UJV	VUJE	VTT	BZN
Material No.	Material (description)	Material Type	Material state / Specimen geometry
1	Main circulation piping - 08Ch18N12T - NPP V1 – initial state	BM	As received							
			Thermal Aged							
2	Pressurizer surge line - 08Ch18N10T - NPP EBO3 – initial state	BM	As received							
			Thermal Aged							
3	Main circulation piping - 08Ch18N12T+WM - NPP V1 – after 28 years in operation	BM	As received							
			Thermal Aged							
		WM	As received							
			Thermal Aged							
		HAZ	As received							
			Thermal Aged							
4	Main circulation piping – triple T-junction - 08Ch18N12T+WM - NPP V1 – after 28 years in operation	BM	As received							
			Thermal Aged							
		WM	As received							
			Thermal Aged							
		HAZ	As received							
			Thermal Aged							
5	Pressurizer surge line - 08Ch18N10T - NPP V1 – after 28 years in operation	BM	As received							
			Thermal Aged							

- Accredited method
- Participation in round robin
- ST** Standard specimen geometry
- M** Miniturized specimen
- BM** Base metal
- WM** Weld metal
- HAZ** Heat affected zone

Specimen type / method

SE, BSE, EDS, WDS, EBSD - 2,5 - 300 000x
SE, BSE, EDS, WDS, EBSD - 5 - 1 000 000x
SE, BSE, EDS - 10 - 100 000x
SE - 20 - 2 000x
SE, BSE, EDS - 5 - 300 000x
SE, BSE, EDS, WDS, EBSD - up to 500 000x
SE, BSE, EDS - 10 - 200 000x

DELISA-LTO – WP2/WP4 Experimental matrix		Experimental Technique		A2.7 - Optical Microscopy			A2.8 - TEM				
		Available / Participating Laboratory		CVR	STUBA	EK-CER	VUJE	VTT	BZN	CVR	STUBA
Material No.	Material (description)	Material Type	Material state / Specimen geometry
1	Main circulation piping - 08Ch18N12T - NPP V1 – initial state	BM	As received								
			Thermal Aged								
2	Pressurizer surge line - 08Ch18N10T - NPP EBO3 – initial state	BM	As received								
			Thermal Aged								
3	Main circulation piping - 08Ch18N12T+WM - NPP V1 – after 28 years in operation	BM	As received								
			Thermal Aged								
		WM	As received								
3b		Thermal Aged									
3c		HAZ	As received								
			Thermal Aged								
4	Main circulation piping – triple T-junction - 08Ch18N12T+WM - NPP V1 – after 28 years in operation	BM	As received								
			Thermal Aged								
		WM	As received								
4b		Thermal Aged									
4c		HAZ	As received								
			Thermal Aged								
5	Pressurizer surge line - 08Ch18N10T - NPP V1 – after 28 years in operation	BM	As received								
			Thermal Aged								

		Specimen type / method
	Accredited method	BF, DF, Polarizer - 5 - 100x
	Participation in round robin	BF, DF, Polarizer - 250x, 500x
ST	Standard specimen geometry	BF, DF, Polarizer - up to 1 100x
M	Miniturized specimen	BF, DF, Polarizer - 100 - 2 000x; 4,7 - 120x
BM	Base metal	BF, DF - 1,25 - 100x
WM	Weld metal	BF, DF, Polarizer - 10 - 6 000x
HAZ	Heat affected zone	STEM, EELS, EDS, In-situ TEM - 6k - 8 000kx
		STEM, EELS, EDS, In-situ TEM - 50 - 2 000kx
		STEM, EELS, EDS - 2k - 2 000kx

